

I. T. 1 HOBBS HOMES

REPAIR AND MAINTENANCE LOG BOOK

SL. NO.	M/C NAME GAS NO.	DATE OF REVISION	TYPE OF MAINTENANCE	REASON MAINTENANCE	REMARKS	INST	SUP	FIN	PRN
01	Refrigerator Lorenst 5.24 M/C NO- 903	16.4.2015	Box type relay is not working	REASON MAINTENANCE Relay is not working on 17.4.2015	New relay working properly & in running condition.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
02	Bottle-cooker, Blue stove, M/C NO- 7771.	15.6.2015	Spring is not produce satisfactory results	Spring is damaged & replaced on 18.6.2015	Very fine & in running condition.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
03	Winders A.C., Blue stove, M/C NO- 5569	23.6.2015	Defectual relay is defective.	Defectual relay is replaced on 23.6.2015	Good the wire in running condition	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
04	Winders A.C., Blue stove, M/C NO- 5569	29.6.2015	Blower motor jam.	Blow Motor motor on 30.6.2015	New the motor in running condition	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
05	Refrigerator, gas type M/C NO- 8587808	16.5.2016 11.7.2016	Thermostat is defective gas & leakage	Thermostat is replaced on 16.5.2016 gas & leakage on 11.7.2016	Running Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
06	First free table dish refrigerator Vidocera M/C NO- 01585	N.A N.A	Routine maintenance Rust like maintenance	After the repair on 12.8.2016 on 13.8.2016 on 13.8.2016	Running Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

P. T. J. HONRAH HOMES

REPAIR AND MAINTENANCE LOG BOOK

SL. No.	M/C NAME AND No. of Refrigerator, Splitter, Holes,	DATE OF REVISION	TYPE OF MAINTENANCE	SECTOR DOWN	MAINTENANCE	REMARKS	INITIALS	SUPPLY	DATE	PRINT
07	M/C No. 155 Ultra Holes,	N.A.	Regular maintenance	N.A.	N.A.	Running	✓	✓	✓	✓
08	Visit Corfen, Holes, M/C no - 08 - 810000	N.A.	Regular maintenance	N.A.	N.A.	Running	✓	✓	✓	✓
09	Deep Freezer, Holes, M/C no - 70076	N.A.	Regular maintenance	N.A.	N.A.	Running	✓	✓	✓	✓
10	Water Corfen, Valve, M/C no - 1001268	N.A.	Regular maintenance	N.A.	N.A.	Running	✓	✓	✓	✓
11	Window A.C., Holes, M/C no - 80160.	N.A.	Regular maintenance	N.A.	N.A.	Running	✓	✓	✓	✓
12	Split A.C. System, Valve, M/C no - 010941 & 07882	N.A.	Regular maintenance	N.A.	N.A.	Running	✓	✓	✓	✓
13	Air conditioning plant, street light, street water, cables, 95 Ton.	N.A.	Regular maintenance	N.A.	N.A.	Running	✓	✓	✓	✓

T.T.I. HONFAH HOMES

REPAIR TRADE AND MAINTENANCE LOG

SL. NO.	M/E NAME AND NO.	DATE OF REPAIR	TYPE OF MAINTENANCE	TRADE	REMARKS	INST	SUP	FM	PKIN
14.	Joe Candy Plant, 027m	N.A	Regular maintenance	N.A.	Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
15.	Cab. Ac. Internal model.	N.A	Regular maintenance	N.A.	Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
16.	Cab. Ac. Condo - units (PULL K)	N.A	Regular maintenance	N.A.	Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
17.	Refrigerator Unit supplied with Rink refrigerator.	N.A	Regular maintenance	N.A.	Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
18.	Refrigerator K5 little supplied with the refrigerator.	05.01.2017	Service done not finished. See 18. See page.	Change bio filter by changing R.M. in refrigerator hood.	Not to be started by running.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
19.	Frost free refrigerator (200 supplied with the brand refrigerator)	N.A	Regular Maintenance	N.A.	Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
20.	Two/Four refrigerator (200 like supplied with the refrigerator)	N.A	Regular Maintenance	N.A.	Running	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

WORK SHEET

DATE: _____ TIME: _____

SIGNATURES

NO.	DESCRIPTION OF WORK	TOOL	MATERIAL	TIME	DATE	INITIALS	PRINT NAME
21	up take and ... welding ... refrigent						
22	Split AC 15 Ton compressor with R22 refrigent	Regular Maintenance					
23	Discharge split AC, 1.5 ton compressor with R22 refrigent.	Regular Maintenance					
24	Carroll AC, 1.5 Ton Compressor with R-22 refrigent	Regular Maintenance					
25	Bench Drilling machine, 25 mm capacity, 200-2000 R.F.M	Regular Maintenance					
26	Grinding machine 200mm, 500 R.F.M	Regular Maintenance					

Master

I.T.I. HOWRAH HOMES

TRADE - RAC

REPAIR AND MAINTENANCE BOOK.

SIGNATURES

SL. NO.	W/C NAME AND ADDRESS	DATE OF BREAKDOWN	TYPE OF MAINTENANCE	EXTENSION	REPAIRS	1ST	SUP	F/N	PR/N
27.	W/c Name and Address Tee Ahng's relay, Vacuum pump, 60-100 R.P.M., Capacity of assembly to form of lbs.	N.A.	Regular maintenance.	N.A.	Running				